

# Upper North Island Security

Summer 10/11 Planning Update  
10<sup>th</sup> December 2010



*Keeping the lights on  
24 hours a day, 7 days a week*

SYSTEM OPERATOR

# UNI Forum

- Purpose
  - Update UNI participants on information and studies completed to date for Summer 10/11.
- Approach
  - Gathered information about summer security issues for Upper North Island.
  - Assumptions made for peak load, power factor, and regional generation availability.
  - Voltage stability limits reviewed across a range of scenarios with currently available information, limits indicative only.
  - Determine whether a contingency plan is required.



# Summer 10/11 – Scenarios Studied

- Potential scenarios considered for Summer 10/11:
  - All equipment in service
  - Outage of a Huntly 250 MW Unit
  - Outage of Huntly Unit 5
  - Outage of Otahuhu B
  - Outage of Otahuhu B and a Huntly 250 MW Unit

Scenario	Huntly Units 2, 4 and 6	Huntly Unit 5	Otahuhu B
1	2 x 250 MW @ 121 MVar 1 x 50 MW @ 38 MVar	1 x 405 MW @ 200 MVar	1 x 395 MW @ 202 MVar
2	1 x 250 MW @ 121 MVar 1 x 50 MW @ 38 MVar	1 x 405 MW @ 200 MVar	1 x 395 MW @ 202 MVar
3	2 x 250 MW @ 121 MVar 1 x 50 MW @ 38 MVar	Out	1 x 395 MW @ 202 MVar
4	2 x 250 MW @ 121 MVar 1 x 50 MW @ 38 MVar	1 x 405 MW @ 200 MVar	Out
5	1 x 250 MW @ 121 MVar 1 x 50 MW @ 38 MVar	1 x 405 MW @ 200 MVar	Out



# Summer 10/11 – Assumptions

- Generation:
  - Southdown = 120 MW from 3 units.
  - Glenbrook = 55 MW.
  - Ngawha = 15 MW.
  - Waikato Block = 600 MW.



# Summer 10/11 – Assumptions

- Load:

	2010	2011	%growth	2011	%growth
	Peak Actual* (MW)	Expected (MW)	from 2010 Actual	Prudent (MW)	from 2010 Actual
Counties Power	44.8	76.0	69.6%	78.9	76.1%
WEL Networks	6.3	8.1	28.6%	8.9	41.3%
Northpower	125.3	150.0	19.7%	155.0	23.7%
NZ Steel	131.5	137.0	4.2%	137.0	4.2%
Top Energy	47.7	52.8	10.7%	59.3	24.3%
Vector	1262.1	1295.0	2.6%	1355.0	7.4%
<b>Total Zone 1</b>	<b>1617.7</b>	<b>1718.9</b>	<b>6.3%</b>	<b>1794.1</b>	<b>10.9%</b>

- No load control assumed.
- 2010 UNI Peak recorded on 25 February at 09:30.
- 2011 Expected/Prudent network loads supplied by distributors.
- \* Actual peaks as recorded concurrent to the Zone 1 2010 peak – individual peaks for network companies is likely to be higher.



# Summer 10/11 – Assumptions

- Zone 1 peak power factor of 0.970
- Albany dynamic reactive support
  - SVC: -100/+100 MVar capacity
- Otahuhu Syn. Condensers
  - SC 1: -29/+52 MVar capacity
  - SC 5: -29/+33 MVar capacity
  - SC 6: -29/+33 MVar capacity
- HVDC = 200 MW North
- Rest of the North Island modelled for GZ loads as per summer peak





# Summer 10/11 – Outages

- Notified transmission outages (as per POCP 10/12/10) to be managed through the normal outage planning process.

Outage Block	Start	End	Type	Planning Status
DRY_GLN_1	11/02/2011 07:30	11/02/2011 17:00	daily	Confirmed
DRY_GLN_2	13/01/2011 07:30	13/01/2011 17:00	daily	Confirmed
	16/03/2011 07:00	16/03/2011 21:00	daily	Tentative
	18/03/2011 07:00	18/03/2011 21:00	daily	Tentative
	23/03/2011 07:30	23/03/2011 21:00	daily	Tentative
	25/03/2011 07:00	25/03/2011 21:00	daily	Tentative
DRY_HLY_1	30/03/2011 07:00	30/03/2011 18:00	daily	Tentative
DRY_OTA_1	16/03/2011 07:00	16/03/2011 21:00	daily	Tentative
	18/03/2011 07:00	18/03/2011 18:00	daily	Tentative
	23/03/2011 07:30	23/03/2011 21:00	daily	Tentative
	25/03/2011 07:00	25/03/2011 21:00	daily	Tentative
HAM_OHW_1	10/03/2011 07:00	12/03/2011 18:00	daily	Tentative
HAM_WKM_1	1/02/2011 07:00	3/02/2011 18:00	daily	Tentative
	7/03/2011 07:00	9/03/2011 18:00	daily	Tentative
HLY_OHW_1	2/03/2011 07:00	2/03/2011 18:00	daily	Tentative
HLY_OHW_2	3/03/2011 07:30	3/03/2011 17:30	daily	Tentative
HLY_OTA_2	15/03/2011 07:00	15/03/2011 21:00	daily	Tentative
	22/03/2011 07:00	22/03/2011 21:00	daily	Tentative
	24/03/2011 07:00	24/03/2011 21:00	daily	Tentative
	28/03/2011 07:30	29/03/2011 17:30	daily	Tentative
HLY_SFD_1	15/03/2011 07:00	16/03/2011 18:00	daily	Tentative
HLY_TWH_1	17/03/2011 07:00	17/03/2011 18:00	daily	Tentative
OHW_OTA_1	7/02/2011 08:00	8/02/2011 17:30	daily	Confirmed
OHW_WKM_1	8/01/2011 06:00	9/01/2011 18:00	continuous	Confirmed
	1/03/2011 07:00	2/03/2011 18:00	daily	Tentative
OTA_SWN_1	8/01/2011 07:30	8/01/2011 20:00	daily	Confirmed
	9/01/2011 07:30	13/01/2011 18:00	daily	Confirmed
OTA_WKM_1	20/02/2011 07:00	21/02/2011 18:00	daily	Tentative
OTA_WKM_2	22/02/2011 07:00	25/02/2011 18:00	continuous	Tentative



# Summer 10/11 – Stability Limits

- Zone 1 voltage stability limits calculated with currently available information

Scenario	Power Factor	N-1 Stability Limit	
		Contingency	UNI Load Limit (MW)
1	0.970	Otahuhu B	2219
2	0.970	Otahuhu B	2104
3	0.970	Otahuhu B	2064
4	0.970	Huntly Unit 5	2059
5	0.970	Huntly Unit 5	1934

➤ Approximately 35 MW of additional benefit if another OTA SC is run.



# Summer 10/11 – Summary

- With currently available information studies show that UNI peak summer demand can be met with all available plant in service
- Based on margins available no current requirements for:
  - NIWA report
  - UNI Contingency plan
- Will be re-assessed if situation changes:
  - Unexpected outages on generators
  - Unexpected outages on transmission plant
- Next update:
  - Reconvene if any generation/transmission issues arise

