

Transpower NZ Ltd System Operator Industry Seminar 13/15 September 2006

Pricing of the 17:30 Trading Period 19th June 2006

TRANSPOWER



SYSTEM OPERATOR
TRANSPOWER NZ LTD

24-7
instant delivery



Introduction

System Operator Industry Seminar

Kevin Small
System Operations Manager
13/15 September 2006

TRANSPower



SYSTEM OPERATOR
TRANSPower NZ LTD

24-7
instant delivery



Agenda

1. Introduction
2. Description of Schedules
3. Standby Residual Checks and Comparison of Schedules
4. Final Pricing – how prices are derived
5. Questions (afternoon tea)
6. Net Free Reserves
7. Dispatch of Reserves
8. Development proposals
9. Discussion




June 19 a significant day for many reasons



June 19 a significant day for many reasons

Loss of supply: Rotorua (53 minutes)


- ROT-TRK 1 (tripping)
- ROT-TRK 2 (planned)



June 19 a significant day for many reasons

Loss of supply: Rotorua (53 minutes)

- ROT-TRK 1 (tripping)
- ROT-TRK 2 (planned)



Local grid emergency 1330 to 2000
Te Matai, Tauranga, Mt Maunganui




June 19 a significant day for many reasons

Loss of supply: Rotorua (53 minutes)

- ROT-TRK 1 (tripping)
- ROT-TRK 2 (planned)

Nation wide grid emergency 1734 to 2000



Local grid emergency 1330 to 2000
Te Matai, Tauranga, Mt Maunganui




Seminar Objectives


- to focus on pricing issues arising from nation wide grid emergency
- provide an understanding of how the price was determined.
- provide an opportunity for relevant pricing questions to be considered



Time Line of Events



Scheduling Pricing and Dispatch (SPD)



Agenda

1. Introduction
2. Description of Schedules
3. Standby Residual Checks and Comparison of Schedules
4. Final Pricing – how prices are derived
5. Questions (afternoon tea)
6. Net Free Reserves
7. Dispatch of Reserves
8. Development proposals
9. Discussion



Description of Schedules

System Operator Industry Seminar

Andrew Twaddle

13/15 September 2006

TRANSPOWER



SYSTEM OPERATOR
TRANSPOWER NZ LTD

24-7
instant delivery



Schedules Produced

Six schedules produced by the Scheduling, Pricing & Dispatch (SPD) software

1. Pre-Dispatch Schedule (PDS)
2. Security Dispatch Schedule (SDS)
3. Schedule of Dispatch Prices and Quantities (SDPQ)
4. Dispatch Schedule (a.k.a. Real Time Dispatch RTD)
5. Real Time Pricing (RTP)
6. Provision/Final Pricing (FP)



Pre-Dispatch Schedule (PDS)

PDS: is the 'ideal' supply and demand schedule

- demand bids supplied by purchasers; the price they will pay for demand
- generation and reserve offers: the prices at which suppliers are willing to provide generation and/or reserve




Security Dispatch Schedule (SDS)

SDS: an internal SO schedule used to assess security


- demand based on:
 - area load forecast from Transpower Energy Management System (EMS)
 - linear regression model
 - updates half hourly based on real time data
- total demand quantity bid provided by 10 large industrials (no price attached)
- generation and reserve offers: prices at which suppliers are willing to provide generation and/or reserve
- SDS exactly the same as the Schedule of Dispatch Prices and Quantities (SDPQ). Solving for different time periods.



18 June 2006 13:00 PDS/SDS




18 June 2006 13:00 PDS/SDS



Time Line SPD Outputs – PDS/SDS

- runs every 2 hours
- provides solution for every trading period during current scheduling period



Dispatch Schedule (RTD)

RTD: schedule uses 5-minute load forecast provided by the coordinator to optimally dispatch system every 5-minutes

- demand based on:
 - actual bus load figures from SCADA/EMS for previous 5-minutes
 - the EMS LF area forecast
 - coordinator forecast at the island level
- generation and reserve offers: the prices at which suppliers are willing to provide generation and/or reserve



Real Time Pricing (RTP)

RTP: schedule of five-minute prices based on system as it existed for the preceding five-minute period

- demand is based on actual load figures from SCADA/EMS for previous 5-minutes
- generation and reserve offers are prices at which suppliers are willing to provide generation and/or reserve



Provisional and Final Pricing (FP)

FP: schedule of thirty-minute prices based on system as it existed for each trading period:

- demand based on actual load figures (from MV90) for each trading period
- generation and reserve offers: prices at which suppliers are willing to provide generation and/or reserve

FP is what should have ideally happened:

- given actual load, but
- ignoring actual energy produced (other than initial conditions)



Summary

- SDS & SDPQ – *Average MWh* forecast
 - Deficit CVP's possible
- PDS – *Average MWh* load bids
 - Deficit CVP's less likely, as bids may not be cleared
- RTD – *Average 5-minute* forecast
 - Deficit CVP's possible
- RTP *Average 5-minute* actual
 - Deficit CVP's possible
- FP – *Average Actual MWh*
 - Deficit CVP's possible



Agenda

1. Introduction
2. Description of Schedules
3. Standby Residual Checks and Comparison of Schedules
4. Final Pricing – how prices are derived
5. Questions (afternoon tea)
6. Net Free Reserves
7. Dispatch of Reserves
8. Development proposals
9. Discussion



Schedules Comparison and the Standby Residual Check Notices

System Operator Industry Seminar
Derrick Westenra
Market Services Manager
13/15 September 2006

TRANSPower



SYSTEM OPERATOR
TRANSPower NZ LTD

24-7
instant delivery



Contents

1. Standby Residual Check and 18 June 13:47 SRC notice
2. Schedule comparisons to Final Pricing
3. Offer changes from 18 June 13:00 through to 19 June 17:29
4. Actual Generation dispatched



SRC Calculations

To determine whether enough:

- generation and reserves offers available after taking off:
 - largest MWMAX offer (assumes largest risk has occurred)
 - frequency keeping bands
 - and including HVDC constraints
- may be short of energy/reserve post event
- demand shedding post event if not enough energy



Why is a second risk considered for reserves?

System Operator has the requirement to get the system back to normal state within 30 minutes following an event....

.....provided sufficient assets are offered by participants



SRC notices issued for 17:30 period on 19th June 2006

- Three notices issued:

notice **1** issued at 13:37 on 18th June 2006

notice **2** issued at 03:05 on 19th June 2006

notice **3** issued at 14:47 on 19th June 2006



SRC notice 1 for 17:30 period on 19th June 2006



Telephone : 0800 488 500
Facsimile : 07 843 7176

To: CAN Energy Traders
From: System Operator

Date: 18 Jun 2006, 13:36

Standby Reserve (CAN) for Insufficient dispatch proposals on 19-Jun-2006 from 17:30 to 18:30

The System Operator advises participants that there are insufficient standby reserves available for the following trading periods:

Following a contingent event:

- There may be insufficient generation reserve available for the System Operator to re-dispatch the system to a secure state (i.e. manage a subsequent contingent event).
- Demand management may be required

Market Day	Time	Period	North Island	South Island	New Zealand
19-Jun-2006	17:30	36	63.006		5.757
19-Jun-2006	18:00	37	96.723		29.044
19-Jun-2006	18:30	38	50.636		

This situation can be alleviated by participants revising their demand and generation offers for those trading periods.

A revision of this notice will be issued if there is any change to the situation advised above.



- demand management may be required if short of energy offers following a CE
- SPD may have infeasible solutions for energy and/or reserve following a CE if short of capacity

Things to note about SRC



- SRC a simple set of calculations derived from SPD solutions
- does not consider transmission constraints that may affect generation
- HVDC only transmission event included in calculations





Energy Capability with Security Concerns (19 June 2006)




Energy Capability with Security Concerns (19 June 2006)




Energy Capability with Security Concerns (19 June 2006)





Energy Capability with Security Concerns (19 June 2006)





6687 6716 7073 7198 7443 7488



Energy Capability with Security Concerns (19 June 2006)




Energy Capability with Security Concerns (19 June 2006)




Energy Capability with Security Concerns (19 June 2006)

- Energy Offer (MW)
- - - Max Capacity (Revised)
- Max Capacity - 60s Res - FK
- Max Capacity - 60s Res - FK - OTC - MTI/WPA
- Energy Required (MW)
- Max Capacity - 60s Res
- Max Capacity - 60s Res - FK - OTC



LOAD

18 June 2006 13:00 FP



LOAD

18 June 2006 13:00 PDS/FP

UNI 2075

UNI 2106

Final Pricing

Pre Dispatch Schedule

Rest NI 2264

Rest NI 2241

SI 2099


SI 2099

DC 846

DC 700

NZ 6438

NZ 6446



18 June 2006 13:00 FP

KTA \$100,000

Final Pricing


Upper NI Stability Constraint
Binding Limit = 755MW

BPE \$814.34

ISL \$788.48

DC 846

NZ 6438



18 June 2006 13:00 PDS/FP

KTA \$100,000

KTA \$475.86

Final Pricing
Pre Dispatch Schedule

Upper NI Stability Constraint
Binding Limit = 755MW

BPE \$814.34

BPE \$287.82

ISL \$788.48


ISL \$280.34

DC 846

DC 700

NZ 6438

NZ 6446







18 June 13:00 summary

	18 June 13:00 SDS
Total ENOF	7443MW
Wind Forecast	54MW
NI 60s Offered	548MW
Load	6445MW







19 June 17:00 summary

	18 June 13:00 SDS		19 June 17:00 SDPQ
Total ENOF	7443MW	-116 	7300MW
Wind Forecast	54MW	+48 	102MW
NI 60s Offered	548MW	-181 	367MW
Load	6445MW	-7 	6438MW



19 June 17:29 summary

	18 June 13:00 SDS		Final total
Total ENOF	7443MW	-152 	7291MW
Wind Forecast	54MW	+57 	111MW
NI 60s Offered	548MW	-181 	367MW
Load	6445MW	-5 	6440MW



17:00 - 17:29 19th

UNI 2075

UNI 1999


Upper NI Stability Constraint
Binding Limit = 755MW

Final Pricing

SDPQ 17:11

Rest NI 2264

Rest NI 2308



SI 2099

SI 2131


DC 846

DC 737

NZ 6438

NZ 6438

17:00 - 17:29 19th



17:00 - 17:29 19th

KTA \$100,000

KTA \$100,000

Upper NI Stability Constraint
Binding Limit = 755MW

BPE \$814.34

BPE \$83,354.12

Final Pricing

SDPQ 17:11


7:11 SDPQ
19.82 Def Gen
20.27 Def NI 60s Res

ISL \$788.48

ISL \$362.20

DC 846

DC 737



17:00 - 17:29 19th

KTA \$100,000

KTA \$100,000

KTA \$100,000

Upper NI Stability Constraint
Binding Limit = 755MW

BPE \$814.34

BPE \$83,354.12

BPE \$83,781.96

Final Pricing

SDPQ 17:11

RTD 17:29

ISL \$788.48

ISL \$362.20


ISL \$ 82,374.06

DC 846


DC 737

DC 810



17:29 RTD
42 Def Gen
18.63 Def NI 60s Res





17:29 Real Time Dispatch





Energy Capability (19 June 2006) - RTD Output





Energy Capability (19 June 2006) - RTD Output





Energy Capability (19 June 2006) - RTD Output





Energy Capability (19 June 2006) - RTD Output





Energy Capability (19 June 2006) - RTD Output




Energy Capability (19 June 2006) - RTD Output




Energy Capability (19 June 2006) - RTD Output




Energy Capability (19 June 2006) - RTD Output





Energy Capability (19 June 2006) - RTD Output




Energy Capability (19 June 2006) - RTD Output




Energy Capability (19 June 2006) - RTD Output



Dispatch and actual energy



Huntly versus dispatch instructions and frequency



Agenda

1. Introduction
2. Description of Schedules
3. Standby Residual Checks and Comparison of Schedules
4. Final Pricing – how prices are derived
5. Questions (afternoon tea)
6. Net Free Reserves
7. Dispatch of Reserves
8. Development proposals
9. Discussion



19 June 2006 – Pricing

System Operator Industry Seminar
Murray Henderson and Derrick Westenra
Market Services
13/15 September 2006

TRANSPower



SYSTEM OPERATOR
TRANSPower NZ LTD

24-7
instant delivery



The objective function

SPD solves to the lowest total cost possible to meet **Physical network requirements** for each trading period.

= Minimum (Offer \$'s x Quantities cleared)

Energy Offers

Reserve Offers – IL, PLSR, TWD



The objective function

- the physical solution is the primary problem being solved by SPD at least cost
- physical network requirements include:
 - transmission network limits
 - risk reserve requirements
 - plant capability
- SPD will rearrange generation to achieve a physical outcome



Marginal prices (nodal prices)

- marginal prices are the outcome to the primary physical SPD solution.
- primary problem solved at least cost, then outcome will be least cost marginal prices
- marginal prices are increment/decrement cost of unit at each bus




Resolution of infeasibilities - process

- Two primary principles are used to resolve infeasibilities:
 - according to actual network operation as far reasonably possible, subject to the EGR's Part G
 - in 1 MW increments until feasible
 - No **Discretion** in resolution approach



The 17:30 infeasible solution - I

Deficit Generation
59.91



North Island

- Uncleared ENOF
ARI 24.3
OTC 43.6
TCC 18.6
- Losses 135.2

South Island

- Uncleared ENOF
0
- Losses 99.1

Objective Function Cost
\$6,226,896
\$5,990,709 CVP + \$236,187 physical



Grid Owner response – infeasibility resolution


- resolution via constraint relaxation:

increase constraint limit in 1MWh increments, stopping once feasible solution achieved or null point achieved.

- UNI Stability Constraint Limit not binding in dispatch/actual and infeasible in final pricing



The 17:30 infeasible solution - II



Grid Owner response – infeasibility resolution


- resolution via addition of North Island 60s Net Free Reserve:

increase 60s Net Free Reserve in 1MWh increments stopping once feasible solution achieved or null position reached.

- only resolution approach possible to obtain a feasible Final Price




The 17:30 feasible solution = final prices




The network energy balance

- The balance equations can be represented thus:




- Subject to:




The 17:30 price sensitivity – marginal prices




$$\text{GENERATION} = \text{Metered LOAD} + \text{LOSSES}$$




$$\text{RISK} = \text{RESERVE}$$




The 17:30 price sensitivity – marginal prices




The 17:30 price sensitivity – marginal prices




$$\text{GENERATION} = +0.001 \text{ WKM2201} + \text{LOSSES}$$




$$\text{RISK} = \text{RESERVE}$$




The 17:30 price sensitivity – marginal prices




$$\Delta \text{ GENERATION} = +0.001 \text{ WKM2201} + \text{LOSSES}$$




$$\text{RISK} = \text{RESERVE}$$




The 17:30 price sensitivity – marginal prices




$$\Delta \text{ GENERATION} = +0.001 \text{ WKM2201} + \text{LOSSES}$$




$$\text{RISK} = \text{RESERVE}$$



The 17:30 price sensitivity – marginal prices



The 17:30 price sensitivity – marginal prices




$$\boxed{+ \text{OTC}} = \boxed{+0.001 \text{ WKM2201}} + \boxed{-\Delta \text{LOSSES}}$$

A teal triangle pointing upwards, positioned below the horizontal line of the equation above.


$$\boxed{\text{RISK}} = \boxed{\text{RESERVE}}$$

A teal triangle pointing upwards, positioned below the horizontal line of the equation above.


The 17:30 price sensitivity – marginal prices




The 17:30 price sensitivity – marginal prices




$$+ \text{ OTC} = +0.001 \text{ WKM2201} + -\Delta \text{ LOSSES}$$




$$+ \text{ OTC} = + \text{ RESERVE}$$




The 17:30 price sensitivity – marginal prices




The 17:30 price sensitivity – marginal prices



The 17:30 price sensitivity – marginal prices



The 17:30 price sensitivity – marginal prices



The marginal price calculation

- change in Energy costs

OTC	$+(0.019637 \times 1,000) \times \420.00	\$8,247.74
HLY	$-(0.019637 \times 1,000) \times \55.04	-\$1,080.85

- change in Reserve costs

IL 6s	$+(0.019637 \times 1,000) \times \130.00	\$2,552.87
HLY 60s	$+(0.019637 \times 1,000) \times \0.24	\$4.71

- change in Total costs \$9,724.47

= Change in Objective Function (x 1,000)

= Nodal Price @ WKM2201




Summary

Final Pricing

HL Y1 -0.01 Energy

WKM2201 +0.001 Load



KTA \$13,063

KTA \$13,063

KTA \$13,063

BPE \$9,636

BPE \$9,636

BPE \$9,636

851.18 North

ISL \$9,418

ISL \$9,418

ISL \$9,418

Objective Function Costs

\$275,597

\$275,698

\$275,607



Agenda

1. Introduction
2. Description of Schedules
3. Standby Residual Checks and Comparison of Schedules
4. Final Pricing – how prices are derived
5. Questions (afternoon tea)
6. **Net Free Reserves**
7. Dispatch of Reserves
8. Development proposals
9. Discussion



Reserve Management Net Free Reserves (NFR)

System Operator Industry Seminar
Derrick Westenra
Market Services Manager
13/15 September 2006

TRANSPower



SYSTEM OPERATOR
TRANSPower NZ LTD

24-7
instant delivery



Contents

- Sources of Net Free Reserves (NFR's)
- How Scheduling Pricing & Dispatch (SPD) and Reserve Management Tool (RMT) interact



Sources of Net Free Reserve (NFR)

- NFR accounts for undispached reserves available in the system (increases NFR)
 - AUFLS
 - Load damping
 - Free hydro reserve in the North Island
 - HVDC reserve sharing
- it also accounts for non-compliant generation (decreases NFR)



How SPD and RMT interact


- SPD SDS produced at 07:00 each day includes next (new) trading day

SPD

- schedule has rolled over NFR's from current day applied to next (new) trading day



How SPD and RMT interact




- cleared risk energy above the NFR must be covered by reserve
- SPD co-optimised risk energy against reserve procured given NFR's



How SPD and RMT interact

- SPD output goes to RMT
 - risk
 - AC CE
 - DC CE
 - DC ECE
 - all energy and reserve cleared
 - NFR values already in SPD



How SPD and RMT interact


- RMT simulates frequency fall for each contingency based on:
 - all energy and reserve cleared
 - risk energy and reserve cleared
 - NFR's from SPD
 - non-compliant plant
- determines if enough reserve available

RMT




How SPD and RMT interact

- dependent on solution outcomes:
 - can decrease NFR's as not enough reserve cleared in SPD
 - can increase NFR's as too much reserve cleared in SPD
 - can remain unchanged as adequate reserve cleared in SPD
- RMT models reserve as that required above system reserve




How SPD and RMT interact


RAF
NFR




- RMT outputs revised numbers to SPD for:
 - CE HVDC NFR
 - ECE HVDC NFR
 - CE AC NFR
- RAF's can only be 0 or 1



How SPD and RMT interact



How SPD and RMT interact – pre-2004



Agenda

1. Introduction
2. Description of Schedules
3. Standby Residual Checks and Comparison of Schedules
4. Final Pricing – how prices are derived
5. Questions (afternoon tea)
6. Net Free Reserves
7. Dispatch of Reserves
8. Development proposals
9. Discussion



Reserve Management Outcomes

19th June 2006 17:30

System Operator Industry Seminar
John Clarke
Investigations and Planning Manager
13/15 September 2006

TRANSPOWER



SYSTEM OPERATOR
TRANSPOWER NZ LTD

24-7
instant delivery



Reserve outcomes for 17:30

- purpose
 - explain why up to 90 MW of reserves still dispatched after reserve dispatch for contingent event ceased at 17:34
- to recap
 - NFR's in RMT are calculation of net free reserve
 - SPD and RMT iterate in successive SPD solves to optimise reserve requirements for dispatch
 - assumption in reserve calculation process - system conditions do not change markedly between last schedule and dispatch



System Reserve cover CE

17:30 on 19 June

NFR Components	FIR NFR	SIR NFR
Non-compliant generation	0	0
AUFLS	0	0
Load Damping	41	0
Free Hydro Reserve	103	0
HVDC Sharing	25	0
Factor	0	0
Total (MW)	169	0

- Input into RMT is 17:11 SDPQ on 19th June 2006
- Load damping applies for load remaining after FIR IL has tripped
- HVDC reserve sharing for AC CE risk only, not DC CE risk



System Reserve cover ECE


17:30 on 19 June

NFR Components	FIR NFR	SIR NFR
Non-compliant generation	-105	-29
AUFLS	1141	1141
Load Damping	44	0
Free Hydro Reserve	111	0
HVDC Sharing	0	0
factor	-11	0
Total (MW)	1180	1112

- Input into RMT is 17:11 SDPQ on 19th June 2006
- Load damping applies for load remaining after AUFLS has tripped
- No HVDC sharing as this is the risk



Reserves for 17:30 on 19 June



- HVDC binding CE risk
- AC CE risk very close
- ECE risk (HVDC) not binding

- ECE RAF not zeroed (risk always covered)
- ECE NFR set to ECE risk - 701MW
- Reserve dispatch up to 90MW FIR and SIR

Why is ECE risk covered

- PPO's require System Operator to avoid cascade failure
 - ie must ensure frequency does not fall outside envelope where NI generators required to remain connected
 - with CE RAF's set to zero SO must still ensure ECE risk is still covered
 - ECE risk not always covered by AUFLS alone
 - significant amount of generating plant with dispensations to trip before ECE limit of 47 Hz



Observations

- If RMT had been run on 1730 dispatch AUFLS would have been sufficient for ECE risk
- Processes and RMT spec do not include rerunning RMT in dispatch
- Current mitigation is for SPD to cover any increase in risk between last SDPQ and dispatch
- With full reserve dispatch to cover CE risk, ECE risk only binds with very high HVDC transfer



Conclusion

- difference in HVDC transfer between RMT solve and actual conditions in dispatch resulted in reserve requirement for ECE in dispatch



Agenda

1. Introduction
2. Description of Schedules
3. Standby Residual Checks and Comparison of Schedules
4. Final Pricing – how prices are derived
5. Questions (afternoon tea)
6. Net Free Reserves
7. Dispatch of Reserves
8. Development proposals
9. Discussion



Development Proposals

System Operator Industry Seminar

Doug Goodwin

System Operator Development Manager

13/15 September 2006

TRANSPower



SYSTEM OPERATOR
TRANSPower NZ LTD

24-7
instant delivery



Development Proposals

- Rule change proposals
- Provision of participant information
- Future development



Publication of SRC information

- Standby Residual Check Notices via Comit
 - publication of the Capacity Residual
- will provide the energy and reserve margins
- all trading periods in scheduling period



Variable Reserves rule change

- increases absolute value and relativities of SPD's constraint violation penalties (CVP's)
- ensures SPD will breach reserve constraint before breaching deficit energy constraint
- this will dispatch all available reserves
- ensures a non zero price for cleared reserve offers
- would not have changed 19th June price outcome



Spring Washer rule change

- a ratio test for High Spring Washer prices
- in final pricing, if ratio of highest nodal price to maximum cleared unconstrained energy offer price is ≥ 5
 - declare spring washer pricing event
 - relieve binding transmission constraint by greater of 1MW or 1%
- would have changed 19th June price outcome by a small amount
 - (MTI WKM constraint)



Demand Side Bidding & Forecasting

- proposed rule change
 - demand bidding replaced with:
 - central demand forecast + non conforming load bids
 - optional dispatchable demand bids
 - 2 schedules linking participant bids and offers directly to security and dispatch schedules and prices
 - improved pricing information
 - improved demand response signals
- benefits
 - enabler for demand response
 - basis of co-ordinated response in shortage of supply
 - basis for providing payment for dispatched demand



Frequency keeping selection

- frequency Keeping (CQAG)
 - improve frequency keeper selection
 - additional/better information to provide transparency
 - better information to understand possible price impact
 - no large gain in schedule information until co-optimised within SPD



Automatic frequency control

- supposed advantages in wholesale energy and ancillary services markets must be investigated
- problems not technical (AFC systems exist in other markets)
- AFC rules
- integration of ancillary and energy markets frameworks



Additional information

- The following slides contain further information and examples that were not presented in the seminars.




The 17:30 price sensitivity – Huntly 1 less 0.01MW ENOF


- the following price sensitivity analysis demonstrates the change in the objective function if you remove 0.01MW of offered energy from Huntly 1.



The 17:30 price sensitivity – Huntly 1 less 0.01MW ENOF




The 17:30 price sensitivity – Huntly 1 less 0.01MW ENOF




The 17:30 price sensitivity – Huntly 1 less 0.01MW ENOF



$$\text{GENERATION} = \text{Metered LOAD} + \text{LOSSES}$$



$$\text{RISK} = \text{RESERVE}$$



The 17:30 price sensitivity – Huntly 1 less 0.01MW ENOF




$$\Delta \text{ GENERATION} = \Delta \text{ LOSSES}$$

$$\text{RISK} = \text{RESERVE}$$


The 17:30 price sensitivity – Huntly 1 less 0.01MW ENOF




$$\Delta \text{GENERATOR 1} \quad \Delta \text{GENERATOR 2} = \Delta \text{LOSSES}$$




$$\text{RISK} = \text{RESERVE}$$



The 17:30 price sensitivity – Huntly 1 less 0.01MW ENOF




$$\boxed{-0.01 @ HLY1} + \boxed{\Delta \text{ GENERATION}} = \boxed{\Delta \text{ LOSSES}}$$



60s Reserve


$$\boxed{\text{RISK}} = \boxed{\text{RESERVE}}$$



The 17:30 price sensitivity – Huntly 1 less 0.01MW ENOF




$$\boxed{-0.01 \text{ @ HLY1}} + \boxed{\Delta \text{ GENERATION}} = \boxed{\Delta \text{ LOSSES}}$$



60s Reserve


$$\boxed{\text{RISK}} = \boxed{\text{RESERVE}}$$



The 17:30 price sensitivity – Huntly 1 less 0.01MW ENOF




$$\boxed{-0.01 \text{ @ HLY1}} + \boxed{+ \text{ @ OTC}} = \boxed{-\Delta \text{ LOSSES}}$$



60s Reserve

$$\boxed{\text{RISK}} = \boxed{\text{RESERVE}}$$



The 17:30 price sensitivity – Huntly 1 less 0.01MW ENOF



$$-0.01 @ \text{ HLY1} + +@ \text{ OTC} = -\Delta \text{ LOSSES}$$

60s Reserve


$$+ \text{ RISK} = \text{ RESERVE}$$



The 17:30 price sensitivity – Huntly 1 less 0.01MW ENOF




$$-0.01 @ \text{ HLY1} + +@ \text{ OTC} = -\Delta \text{ LOSSES}$$



60s Reserve


$$+ \text{ OTC} = + \text{ RESERVE}$$



The 17:30 price sensitivity – Huntly 1 less 0.01MW ENOF




$$-0.01 @ \text{HLY1} + +@ \text{OTC} = -\Delta \text{LOSSES}$$



60s Reserve


$$+ \text{OTC} = + \text{RESERVE}$$



The 17:30 price sensitivity – Huntly 1 less 0.01MW ENOF




$$-0.01 \text{ @ HLY1} + \text{@ OTC} - \text{Generator 3} = -\Delta \text{ LOSSES}$$




60s Reserve

$$+ \text{OTC} = + \text{RESERVE}$$



The 17:30 price sensitivity – Huntly 1 less 0.01MW ENOF




$$-0.01 \text{ @ HLY1} + \text{ @ OTC} - \text{ HLY} = -\Delta \text{ LOSSES}$$

60s Reserve


$$+ \text{ OTC} = + \text{ HLY}$$



The 17:30 price sensitivity – Huntly 1 less 0.01MW ENOF




$$-0.01 @ \text{HLY1} + 0.2051 @ \text{OTC} - 0.2051 @ \text{HLY} = -0.01$$




60s Reserve

$$+0.2051 @ \text{OTC} = +0.2051 @ \text{HLY}$$



The 17:30 price sensitivity – Huntly 1 less 0.01MW ENOF



Energy

$$-0.01 \times \$55.01$$

+

$$\frac{+0.2051 \times \$420}{-0.2051 \times \$55.04}$$

=

$$= \$74.30$$

60s Reserve

$$+0.2051 \times \$0.24$$

=

$$= \$0.05$$

6s Reserve

$$+0.2051 \times \$130$$

=

$$= \$26.66$$

$$= \$101.01$$



1700

System Operator Industry Seminar
Murray Henderson
Market Services
13/15 September 2006

TRANSPower




SYSTEM OPERATOR
TRANSPower NZ LTD

24-7
instant delivery



The 17:00 infeasible solution

North Island
60s Reserve Deficit
2.19MWh



HVDC Pole1A
Out of Service

85
+18 60s
 103 > 88 FKK limit
 ∴ 15MWh FKK + 60s violation

North Island

- Uncleared ENOF
 OTC 67MWh
 TCC 42MWh
 WHI 5MWh

South Island


- Uncleared ENOF
 270MWh

Objective Function Cost
 \$2,545,520
 \$2,256,514 CVP + \$289,006 physical

The 17:00 feasible solution

FKK WKA + 60s constraint removed +3MWh of NI 60s Net Free Reserve

HVDC Pole1A Out of Service



North Island

- Uncleared ENOF
OTC 67MWh
TCC 42MWh
WHI 5MWh


South Island

- Uncleared ENOF
270MWh


Objective Function Cost
\$287,877

Tuai actual generation vs FKK limits

Tuai FKK 1700 - 1729 19 June 06




Tokaanu's bona fide reduction



■ 14:13 Offer ■ 14:56 Offer ■ 16:45 Offer ■ 17:26 Offer

TCC dispatch versus actual


TCC TREND vs Dispatch Instructions 1730



OTC dispatch versus actual

OTC TRENDR vs Dispatch instructions 1730

CE RAFs set to



17:30 Trading Period

Why 23MW of North Island 60s NFR?

- Existing 60s Deficit 18.63
- Deficit Generation KTA0331 3.38
- Increase in losses 0.99
- Total 23



How SPD and RMT interact

- DC Contingent Event Risk Model

$$\text{Risk}_{\text{CE}} \geq \text{RAF}_{\text{CE}}(\text{HVDCflow} - \text{RiskOffset}_{\text{CE}})$$

- Generator Contingency Risk Model

$$\text{Risk}_{\text{Gen}} \geq \text{RAF}_{\text{Gen}}(\text{Gen} - \text{RiskOffset}_{\text{Gen}})$$

- Manual Risk

$$\text{Risk}_{\text{Man}} \geq \text{RAF}_{\text{Man}}(\text{ManualRisk} - \text{RiskOffset}_{\text{Man}})$$

- DC Extended Contingent Event Risk Model

$$\text{Risk}_{\text{ECE}} \geq \text{RAF}_{\text{ECE}}(\text{HVDCflow} - \text{RiskOffset}_{\text{ECE}})$$

